




# PRODUCT TYPE A8



REFERENCE NUMBER: 3.1.0

EXAMPLE PART NUMBERING:  
ABBF/NP/20R/M20

<b>A</b>	Gland for Unarmoured Cables
<b>8</b>	Silicone Seal for flat cables
<b>B</b>	Brass (B) / Stainless Steel (S)
<b>F</b>	Multiple Certification
<b>NP</b>	Nickel Plated
<b>20R</b>	Gland shell size
<b>M20</b>	M20 x 1.5mm Male Entry Thread

OPTIONAL  
ACCESSORIES:

<b>LOCKNUT</b>	Brass (ACBLN) / Stainless Steel (ACSLN)
<b>EARTH TAG</b>	Brass (ACBET) / Stainless Steel (ACSET)
<b>IP WASHERS</b>	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
<b>SERRATED WASHERS</b>	Stainless Steel (ACSSW)

<b>IP RATING:</b>	IP66 & IP68 (50 metres - 7 Days)
<b>OPERATING TEMP:</b>	Silicone Seals -60°C to +180°C
<b>MATERIALS:</b>	Brass or Stainless Steel
<b>PLATING:</b>	Electroless Nickel

CABLE GLAND SELECTION TABLE  
(ALL DIMENSIONS IN mm)

Gland Size	Entry Thread Size		ISO Thread Length [B]	Cable Outer Sheath [D]				Nominal Protusion Length [L]	Dimensions/Weight (Metric Versions)			Metric Thread Shroud Size
				Width		Thickness			Across Flats [A]	Across Corners	Weight Kgs (Metric)	
	Metric	NPT		Min	Max	Min	Max					
20S	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	6.3	11.7	4.0	7.0	33	30.0	33.0	0.104	N/A
20R	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	8.1	13.5	5.8	6.2	33	30.0	33.0	0.104	N/A
20	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	10.3	13.5	5.6	9.0	33	30.0	33.0	0.103	N/A
** 25	M25 x 1.5	3/4" or 1"	16	10.6	16.2	4.0	7.0	31	37.6	41.4	0.162	N/A

NOTES

- \*\* Size 25mm is only ATEX & IECEx certified.
- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available

## Single Compression Gland Designed for Armoured and unarmoured cables

Ex d : Ex e : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2 : AEx e : AEx ta

PART NUMBERS:

A	8	B	F
S			



### PRODUCT DESCRIPTION

"A8" type glands are certified Flameproof Ex d, Increased Safety Ex e, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex d sealing and have been tested to IP66 and IP68 to 50 metres. The A8 version is designed to accommodate unarmoured and armoured cables where sealing and retention is required only on the outer sheath.

### COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31  
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529  
UL514B, UL1203, ANSI/UL 60079-0/7, ISA 60079-31

CERTIFICATION:

<b>ATEX</b>	II 1D 2G Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc
<b>IECEx</b>	Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da
<b>NEC - USA</b>	Class I Zone 1 AEx e IIC Gb / Class II Zone 20 AEx ta IIIC Da Class II Division 1, Groups E, F & G Class III, Enclosure Type 4X
<b>EAC</b>	Exd IICU / Exe IIU / ExnR IIU
<b>SAC - China</b>	Ex d IIC / Ex e IIC
<b>INMETRO - Brazil</b>	Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc
<b>UKRAINE</b>	Ex d IIC X / Ex e II X
<b>CCoE</b>	Petroleum Rules 2002 (PESO)
<b>ABS</b>	Specified ABS Rules
<b>LLOYD'S</b>	Enclosure Systems (Part 1B)
<b>RMRS</b>	Part XI of RS Rules for the classification & construction of sea-going ships (ed. 2014)

CERTIFICATION No:

<b>ATEX</b>	SIRA 01ATEX1270X & SIRA 09ATEX1221X
<b>IECEx</b>	IECEx SIR 05.0020X
<b>NEC - USA</b>	CSA 2627370
<b>EAC</b>	RU C-GB.Г506.B.00098
<b>SAC - China</b>	NEPSI GYJ16.1398X
<b>INMETRO - Brazil</b>	NCC 13.2187 X
<b>UKRAINE</b>	UA.TR.047.C.0408-13 & 2937
<b>CCoE - India</b>	PESO P365300/2 & P365300/6
<b>ABS</b>	14-LD463991-1-PDA
<b>LLOYD'S</b>	10/00056(E1)
<b>RMRS</b>	14.02755.315

- machining techniques and will not have a full form thread for the entire length. Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for gland kits, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
  - Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.